


Example: Typical footing to connect a new frost wall to an existing full-depth foundation wall

Per Section 9.12.2.1 of the National Building Code, excavations for foundations are required to extend to undisturbed soil. The footing depth for a foundation being used for an addition is required to extend to meet the depth of the existing foundation.



Per Section 9.15.3.9 of the NBC, the vertical rise of a step footing is limited to a <u>maximum</u> of 600mm and the horizontal run is required to be a <u>minimum</u> of 600mm. Maintain the thickness of the strip footing throughout the rise and run of the step footing.

This pamphlet has no legal status and cannot be used as an official interpretation of the various codes and regulations currently in effect.Revised 1/18/16City Of Summerside-Technical Services